

Bidding Addendum

Addendum No. 2: Life Safety Code Improvements, Building 15 & 16, Catawba Hospital
Project No. 720-16726-06
IFB No. 09-007

To: All Bidding Document Holders of Record

From: Wiley|Wilson
Richmond, Virginia

Addendum Date: September 29, 2009

This Addendum contains 2 page and listed attachments and forms a part of the bidding documents and modifies the Project Manual and Drawings dated June 18, 2009, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.


PREBID QUESTIONS

1. 16725, paragraph 1.02 - "Can an acceptable equivalent access control system other than Galaxy be proposed if approved by the owner?"
Answer, Yes.
2. 16725, paragraph 1.01 - "Part-J, will the interface be relay-based and if so, how many inputs/outputs does the Infinity Solutions system have?"
Answer, This information will be supplied by the owner. Provide the capability to interface with a relay-based system with one input and one output dry contact.
3. 16725, paragraph 1.01 - "Parts B & C, Does the owner want both card and pin before lock can be opened or card or pin?"
Answer, both pin and card to open door.
"Part G – Does the owner want badge printer to include a laminator?"
Answer, yes.
"Part H – Will the owner be providing PC hardware, monitors, mice, and keyboard?"
Answer, yes.

DOCUMENT CLARIFICATION

Wiremold shall be a one-piece surface steel raceway, similar to Wiremold Wire Management Systems V Series, and shall be installed in all finished spaces with exception of the stairwells which may be EMT. Wiremold shall be sized for the number of wires installed.

End of Addendum No. 2

WILEY|WILSON

Norman B. Downey, P.E.
Vice President