

# AIR DEVICE SCHEDULE

MARK	SERVICE	TYPE	MAX. CFM	NECK SIZE	SHELL SIZE	THROW	SP IN. WG.	NC	REMARKS
SD-1	SUPPLY	SURFACE MOUNT	279	N/A	12 X 12	4-WAY	0.09	22	TITUS - MODEL TMS, 360 DEGREE PATTERN
SD-2	SUPPLY	SURFACE MOUNT	550	N/A	24 X 24	4-WAY	0.05	21	TITUS - MODEL TMS, 360 DEGREE PATTERN
SD-3	SUPPLY	LAY-IN	550	N/A	24 X 24	4-WAY	0.05	21	TITUS - MODEL TMS, 360 DEGREE PATTERN
SD-4	SUPPLY	SURFACE MNT ROUND	245	N/A	12" DIA	N/A	0.03	24	TITUS - MODEL TMR, 360 DEGREE PATTERN
RG-1	RETURN	PERFORATED SURFACE MOUNT	175	N/A	12 X 12	4-WAY	0.09	23	TITUS - MODEL PAR, 3/16" PERFORATED HOLES 1/4" STAGGERED CENTERS
RG-2	RETURN	PERFORATED SURFACE MOUNT	393	N/A	24 X 24	4-WAY	0.09	25	TITUS - MODEL PAR, 3/16" PERFORATED HOLES 1/4" STAGGERED CENTERS
RG-3	RETURN	PERFORATED LAY-IN	393	N/A	24 X 24	4-WAY	0.09	25	TITUS - MODEL PAR, 3/16" PERFORATED HOLES 1/4" STAGGERED CENTERS
ER-1	EXHAUST	PERFORATED SURFACE MOUNT	150	N/A	12 X 12	4-WAY	0.07	19	TITUS - MODEL PAR, 3/16" PERFORATED HOLES 1/4" STAGGERED CENTERS
ER-2	EXHAUST	PERFORATED SURFACE MOUNT	273	N/A	24 X 24	4-WAY	0.06	21	TITUS - MODEL PAR, 3/16" PERFORATED HOLES 1/4" STAGGERED CENTERS

By: D.CATALON Date: 8/25/09 Proj. No.: 08103 Rev: Scale: AS SHOWN Page: 1 of 1 File: 08103M23

Client: SOUTHWESTERN VIRGINIA TRAINING CENTER

Project: REPLACE DUCTWORK BUILDING 1,2,9 AND 10

Subject: AIR DIFFUSER SCHEDULE

## KINCAID • BRYANT

A KINCAID BRYANT, PC COMPANY

MECHANICAL • ELECTRICAL • PLUMBING • STRUCTURAL • FIRE PROTECTION

LYNCHBURG

1085 VISTA PARK DRIVE, SUITE A • FOREST, VA 24551  
PHONE: 434-846-6510 • FAX: 434-846-0005

RICHMOND

9464 CHAMBERLAYNE RD • MECHANICSVILLE, VA 23116  
PHONE: 804-730-0011 • FAX: 804-730-4012